

7. Security Measures

7. Security Measures

7.1 NACCS Center hardware

Improve the reliability of NACCS Center hardware using the measures described below.

- (1) The configuration of NACCS Center server shall be at least duplexed. When NACCS Center devices or network equipment are affected by disaster or fails, online operation resumes by switching the operation to Backup center. Switching to Backup center is conducted by NACCS Center side, so users do not need to perform switching.

- (2) The building where NACCS Center hardware is installed shall be equipped with a permanent power supply and an in-house generator to enable continuous operation.